

# Certificate

## Hygiene conformity test

**Tested type series** S40, S60, I60

**Device type** air-handling unit

**Manufacturer** Rosenberg Ventilatoren GmbH, Maybachstraße 1/5/9,  
74653 Künzelsau - Gaisbach

**Date and place of test** 17<sup>th</sup> and 18<sup>th</sup> June 2009, Rosenberg Ventilatoren GmbH,  
Werk 3 - Sachsen, Industriestraße A6, 01612 Glaubitz

**Test criterion** Hygiene requirements for the following standards:

**Standard climatisation**

VDI 6022, page 1 (04/06) ✓  
VDI 3803 (10/02) ✓  
ÖNORM H 6021 (09/03) ✓  
SWKI VA104-01 (04/06) ✓  
DIN EN 13779 (09/07) ✓

**Hospitals**

DIN 1946, part 4 (12/08) ✓  
ÖNORM H 6020 (02/07) ✓  
SWKI 99-3 (03/04) ✓

**Test result** Hygiene conformity is  not confirmed  
 confirmed subject to conditions  
 confirmed without conditions

**Validity period** 3 years: 07.2009 – 07.2012

**Registration number** HKP/D/086-1/8/RB/0709/0712/MZ



geprüft durch **ILH BERLIN**

*M. Mörzt*

Expert appraiser: Dr.-Ing. M. Mörzt

Berlin, 14<sup>th</sup> September 2009

Within the scope of the hygiene conformity test, the hygiene-relevant requirements of the regulations listed under the "test criteria" and marked with a "✓" were tested. Requirements referred to in other regulations were not tested. The hygiene conformity test does not include toxicological tests or assessments of the materials used in the tested equipment series.