

CERTIFICAT

CERTIFICADO

證明書

СЕРТИФИКАТ

CERTIFICATE

ZERTIFIKAT



Herewith it is confirmed to the company

Rosenberg Ventilatoren GmbH

in

D-74653 Künzelsau - Gaisbach
for the operated fan test rig

„Großer Prüfstand“

located in

D-74653 Künzelsau – Gaisbach

for the volumetric flow range of 3,000 m³/h to 40,000 m³/h
and a pressure range up to 2,300 Pa,

based on the positive results of the completed tests regarding compliance
with the requirements of the Standard

DIN EN ISO 5801:2018-04

to identify this with the following
TÜV SÜD Certification Mark.



This certificate is valid until 2026-12-31

Certificate Registration Number: 08/11/01 (Revision 01)



Certification Body for Products
Refrigeration and Air-Conditioning
Munich, 2024-11-06



CERTIFICAT

CERTIFICADO

證明書

СЕРТИФИКАТ

CERTIFICATE

ZERTIFIKAT



Herewith it is confirmed to the company

Rosenberg Ventilatoren GmbH

in

D-74653 Künzelsau - Gaisbach
for the operated fan test rig

„Mittlerer Prüfstand“

located in

D-74653 Künzelsau – Gaisbach

for the volumetric flow range of 100 m³/h to 11,000 m³/h
and a pressure range up to 3,000 Pa,

based on the positive results of the completed tests regarding compliance
with the requirements of the Standard

DIN EN ISO 5801:2018-04

to identify this with the following
TÜV SÜD Certification Mark.



This certificate is valid until 2026-12-31

Certificate Registration Number: 08/11/02 (Revision 01)



Certification Body for Products
Refrigeration and Air-Conditioning
Munich, 2024-11-06

